

EC Statement of conformity

Herewith

DEC International®

declares that

the thermal and acoustical insulated flexible duct
named:

Sonodec®25

Classified : B – s1,d0

has been tested and classified according :

EN 13501-1:2007+A1:2013

*“Fire classification of construction products and building elements –
Part 1: Classification using test data from reaction to fire tests”
(Report nr.RC160330)*

Test Methods:

NF-EN 13823:2013 / NF-EN 13823+A1:2015
*“Reaction to fire tests for building products –
Building products excluding floorings exposed to
the thermal attack by a single burning item”*

NF-EN-ISO 11925-2:2013
*“Reaction to fire tests – Ignitability of building products
subjected to direct impingement of flame –
Part 2: Single-flame source test”*